



7800 O Street, Suite 100
Lincoln, NE 68510
(402) 489-7627

MECHANICAL
ELECTRICAL
FIRE PROTECTION

ADDENDUM NO. #2

DATE: February 8, 2019

PROJECT: Norfolk Veterans Home Fire Sprinkler System Improvements
GE #28034

This addendum is issued to all plan holders of record prior to receipt of proposals. This addendum modifies only those portions of the proposed Contract Documents as described below and all other portions of the proposed Contract Documents remain unchanged and in full effect.

ADDENDUM ITEMS.

SPECIFICATIONS:

1. No Items.

DRAWINGS:

1. Refer to Sheet FS-1, Corrosion Management System Schedule:
The nitrogen generator needs to be a larger system to provide the capacity needed for the system. The nitrogen generator shall be Engineered Corrosion Solutions Model PGEN-30. Power requirements are 2 amps at 120 volts. The cabinet size is 24.5" wide x 52.5" high x 8.5 inches deep.

ATTACHMENTS

None.

END OF ADDENDUM