

# Kearney Youth Rehabilitation Treatment Center MAINTENANCE REROOF

## Addendum 2

Kearney, Nebraska  
1845

Wilkins Architecture Design Planning  
2908 West 39<sup>th</sup> Street, Suite A  
Kearney, Nebraska 68845  
308-237-5787

Date Issued: February 18, 2019  
Bid Date: February 20, 2019

TO ALL BID DOCUMENT HOLDERS OF RECORD:

Acknowledge receipt of this addendum by inserting its number in the space provided on the BID FORM. Failure to do so may subject Bidder to disqualification. This Addendum forms a part of the BIDDING DOCUMENTS and modifies them as follows.

-----

**Addendum 2 – 1      Specification Section – Advertisement for Bids**

Bid date will be changed to be **“Wednesday February 27<sup>th</sup>, 2019 at 2:00 PM”** in lieu of “Wednesday February 20<sup>th</sup>, 2019, 2:00 PM.” Location where bids will be received will remain unchanged.

**Addendum 2 – 2      Sheet – A1.1 Roof Plan**

At description of Roof Type RA-2, Delete “U-0.029 (MIN.) R-34” and replace with “U-0.0435 (MIN.) R-23”