

# Addendum 2



---

**Date:** 12/3/14

**Project Name:** LRC Building 9 HVAC Upgrade

**Project #:** 14078

---

**Mechanical Drawing Items:**

MD1. Sheet M1-1 – Basement & First Floor Plans - Mechanical

A. Plan 3:

1. Add the following Sheet Note 27 next to the supply ductwork, separately, for BCU-1 and BCU-2:

“Provide smoke detector in supply ductwork upstream of any branch connection. Detector shall shut unit down. Provide audible alarm to main reception desk area.”

---

**Submitted By:** Chris Hawk